



Czech

INSPECTION CERTIFICATE

File number **11.270.740**

Issued according to EN ISO/IEC 17020 to the organization:

METEL s.r.o.
Žižkův kopec 617
552 03 Česká Skalice
Czech Republic

On the basis of results conducted 2017-08-11, which are listed under Inspection report of TÜV SÜD Czech file No.: 11.270.738 we hereby confirm conformity of the below mentioned device:

Name:	Outdoor steel cabinet
Type:	OH6425-C4.A12.R.PB4.SE.HP
Serial number:	20160507002
Year of production:	2017
Rated voltage:	230V/50Hz VAC
IP code:	IP66
Manufacturer:	METEL s.r.o., Žižkův kopec 617, 552 03 Česká Skalice

With requirements of the following regulations/standards which were the basis for its evaluation:

ČSN EN 61439-1ed.2:2012, ČSN EN 55032:2012 ed.2:2016,
ČSN EN 55024 ed.2:2011+A1:2016

Valid conditions:

This Inspection Certificate relates only to the inspection subject. Other conditions are stated in the Inspection Report File No. 11.270.738 from 2017-08-11.

in Prague, on 2017-08-11



On behalf of TÜV SÜD Czech s.r.o.: Ing. Michal Svrček

TÜV SÜD Czech s.r.o. • Novodvorská 994 • 142 21 Prague 4 • Czech Republic • certification@tuv-sud.cz