



Czech

# INSPECTION CERTIFICATE

File number **10.700.789**

Issued according to EN ISO/IEC 17020 to the organization:

**METEL s.r.o.**  
**Žižkův kopec 617**  
**552 03 Česká Skalice**  
**Czech Republic**

On the basis of results conducted 2017-04-18, which are listed under Inspection report of TÜV SÜD Czech file No.: 10.700.787 we hereby confirm conformity of the below mentioned device:

Name:	<b>Outdoor steel cabinet</b>
Type:	<b>OH3215</b>
Serial number:	<b>20160507002</b>
Year of production:	<b>2016</b>
Rated voltage:	<b>230V/50Hz VAC</b>
IP code:	<b>IP66</b>
Manufacturer:	<b>METEL s.r.o., Žižkův kopec 617, 552 03 Česká Skalice</b>

With requirements of the following regulations/standards which were the basis for its evaluation:

ČSN EN 61439-1ed.2:2012, ČSN EN 55032:2012 ed.2:2016,  
ČSN EN 55024 ed.2:2011+A1:2016

## Valid conditions:

This Inspection Certificate relates only to the inspection subject. Other conditions are stated in the Inspection Report File No. 10.700.787 from 2017-04-18.

in Prague, on 2017-04-18



On behalf of TÜV SÜD Czech s.r.o.: **Ing. Vladimír Řeháček**

TÜV SÜD Czech s.r.o. • Novodvorská 994 • 142 21 Prague 4 • Czech Republic • [certification@tuv-sud.cz](mailto:certification@tuv-sud.cz)