



Czech

INSPECTION CERTIFICATE

File number 12.773.331

Issued according to EN ISO/IEC 17020 to the organization:

**METEL s.r.o.
Žižkův kopec 617
552 03 Česká Skalice
Czech Republic**

On the basis of results conducted 2019-11-21, which are listed under Inspection report of TÜV SÜD Czech file No.: 12.773.330 we hereby confirm conformity of the below mentioned device:

Name:	Outdoor steel cabinet with Thermo Set for OH Cabinets
Type:	OH8625-C10.C4.A12.R.PB4.SE.Hx
Thermal set type:	OH-Thermo-Set-HV
Serial number:	---- (prototype)
Year of production:	2019
Rated voltage:	230V/50Hz VAC
Rated current:	10 A max.
IP code:	IP55
Manufacturer:	METEL s.r.o., Žižkův kopec 617, 552 03 Česká Skalice

With requirements of the following regulations/standards which were the basis for its evaluation:

ČSN EN 61439-1 ed.2:2012, ČSN EN 55032 ed.2:2017, ČSN EN 55024 ed.2:2011+A1:2016

Valid conditions:

This Inspection Certificate relates only to the inspection subject. Other conditions are stated in the Inspection Report File No. 12.773.330 from 2019-11-21.

in Prague, on 2019-11-21

**On behalf of TÜV SÜD Czech s.r.o.: Ing. Michal Svrček**TÜV SÜD Czech s.r.o. • Novodvorská 994 • 142 21 Prague 4 • Czech Republic • certification@tuv-sud.cz