



Czech

# INSPECTION CERTIFICATE

File number **12.776.068**

Issued according to EN ISO/IEC 17020 to the organization:

**METEL s.r.o.**  
**Žižkův kopec 617**  
**552 03 Česká Skalice**  
**Czech Republic**

On the basis of results conducted 2019-11-22, which are listed under Inspection report of TÜV SÜD Czech file No.: 12.776.062 we hereby confirm conformity of the below mentioned device:

Name:	<b>Outdoor steel cabinet with Thermo Set for OH Cabinets</b>
Type:	<b>OH6425-C4.A12.R.PB4.SE</b>
Thermal set type:	<b>OH-Thermo-Set-HV</b>
Serial number:	<b>20191011001</b>
Year of production:	<b>2019</b>
Rated voltage:	<b>230V/50Hz VAC</b>
Rated current:	<b>4 A max.</b>
IP code:	<b>IP55</b>
Manufacturer:	<b>METEL s.r.o., Žižkův kopec 617, 552 03 Česká Skalice</b>

With requirements of the following regulations/standards which were the basis for its evaluation:

ČSN EN 61439-1 ed.2:2012, ČSN EN 55032 ed.2:2017, ČSN EN 55024 ed.2:2011+A1:2016

## Valid conditions:

This Inspection Certificate relates only to the inspection subject. Other conditions are stated in the Inspection Report File No. 12.776.062 from 2019-11-22.

in Prague, on 2019-11-22



On behalf of TÜV SÜD Czech s.r.o.: *Ing. Michal Svrcek*

TÜV SÜD Czech s.r.o. • Novodvorská 994 • 142 21 Prague 4 • Czech Republic • [certification@tuv-sud.cz](mailto:certification@tuv-sud.cz)